

>B< PRESS TUBE SIZE COMPATIBILITY

|                     |  | COPPER TUBE TO EN1057 |     |                     |     |                    |     |
|---------------------|--|-----------------------|-----|---------------------|-----|--------------------|-----|
| TUBE<br>O/D<br>(mm) |  | TEMPER R220           |     | TEMPER R250         |     | TEMPER R290        |     |
|                     |  | WALL THICKNESS (mm)   |     | WALL THICKNESS (mm) |     | WALL THICKNESS(mm) |     |
| 12                  |  | 0,6                   | -   | 0,8                 | 1,0 | 1,0                | -   |
| 14                  |  | 1,0                   | -   | 1,0                 | 1,0 | 1,0                | -   |
| 15                  |  | 1,0                   | -   | 0,7                 | 1,0 | 1,0                | -   |
| 16                  |  | 1,0                   | -   | 1,0                 | 1,0 | 1,0                | -   |
| 18                  |  | 1,0                   | -   | 0,8                 | 1,0 | 1,0                | -   |
| 22                  |  | 1,0                   | 1,2 | 0,9                 | 1,1 | 1,0                | 1,5 |
| 28                  |  | -                     | -   | 0,9                 | 1,2 | 1,0                | 1,5 |
| 35                  |  | -                     | -   | 1,2                 | -   | 1,0                | 1,5 |
| 42                  |  | -                     | -   | 1,2                 | -   | 1,0                | 1,5 |
| 54                  |  | -                     | -   | 1,2                 | -   | 1,2                | 2,0 |
| 66,7                |  | -                     | -   | 1,2                 | -   | 1,2                | 2,0 |
| 76,1                |  | -                     | -   | 1,5                 | -   | 1,5                | 2,0 |
| 88,9                |  | -                     | -   | -                   | -   | -                  | 2,0 |
| 108                 |  | -                     | -   | 1,5                 | -   | 1,5*               | 2,5 |

\*108 x 1.5mm – Additional requirement over EN1057 for the min wall thickness must not be below 1.4mm.