DOOR POSITIONS & HANDINGS

105X2180MM

PLATFORM

В


ALTERNATIVE PLATFORM SIZES

Cibes Lift Group

CIBES LIFT UK LTD

HEAD OFFICE CHAPEL HOUSE LEICESTER ROAD, LOUGHBOROUGH LE11 2AF TELEPHONE: 01509 436 022

CENTRE OF EXCELLENCE
UNITS 2 & 3 ENTERPRISE HOUSE, THOMLINSON
ROAD, HARTLEPOOL, TS25 1NS TELEPHONE: 01429 426222



ALTERNATIVE PLATFORM SIZES

	FOOTPRINT	PLATFORM SIZE
_ *	1630 WIDE X 2380 LONG	1105 WIDE X 2180 LONG
נ	1930 WIDE X 2180 LONG	1405 WIDE X 1980 LONG
ົວ	1930 WIDE X 2680 LONG	1405 WIDE X 2480 LONG

*SIZE SHOWN ON THIS DRAWING

DOOR OPENING WIDTH 1000mm

LIFTING EYE OR BEAM TO BE SUPPLIED BY OTHERS [SWL 500KG] APPROX 250MM ABOVE

ACCESS REQUIRED FOR ELECTRICAL


COMPARTMENT AND EMERGENCY


BATTERY LOWERING


TYPICAL INCOMING POWER SUPPLY


OTHERS I

LOCATION [SUPPLIED AND FITTED BY









NOTE: GLASS SHAFT PANELS ARE SHOWN FOR ILLUSTRATION PURPOSES ONLY. WHITE STEEL SHAFT PANELS ARE PROVIDED AS STANDARD.

REFER TO QUOTATION FOR DETAILS

GENERAL NOTES

1) A 130MM DEEP PIT IS REQUIRED ON SITE FOR THE LIFT TO SIT INTO TO GIVE LEVEL ACCESS AT THE LOWER FLOOR (130MM PIT +6MM/-0MM)

2) IT WILL BE NECESSARY FOR THE BUILDER TO PROVIDE SUPPORT FOR THE LIFT ON SIDE D

3) THE SUPPORT WALL MUST BE PLUMB TO ±5MM. THE RELATIONSHIP BETWEEN THE LIFT BASE AND THE WALL / FIXING LOCATION IS TO BE PLUMB AND SOLIARE -0/+10MM

4) THE FLOOR TO CEILING HEIGHT REQUIRED IS A MINIMUM OF 2300 (WITH PIT - 2430 NO PIT). A CLEAR HEADROOM OF 2400MM WOULD BE REQUIRED ABOVE THE UPPER FLOOR LEVEL IN ORDER TO FIT A STANDARD UNIT.

5) THE STANDARD COLOUR OF THE PLATFORM LIFT SHAFT PANELS IS WHITE RAL 9016 FINISH, OTHER COLOURS ARE AVAILABLE ON REQUEST.

6) THE UNIT IS RATED AT 1000KG AS STANDARD

7) OTHER LIFT SIZES ARE AVAILABLE. PLEASE CONTACT THE OFFICE FOR OTHER OPTIONS.

ELECTRICS

THREE PHASE SUPPLY:
A PERMANENT 415V 3 PHASE 50HZ SUPPLY IS REQUIRED (4 WIRE - NEUTRAL & EARTH) PROTECTED BY A 20 AMP FUSED AND LOCKABLE IS ISOLATOR TO BE POSITIONED EXTERNALLY OF THE LIFT ENCLOSURE. SUPPLIED AND FITTED BY OTHERS WITHIN 500MM OF THE ELECTRICAL COMPARTMENT.

A8000

DO NOT SCALE - IF IN DOUBT ASK

Α	24/11/2016	INITIAL DRAWING	DRAWN BY:	CT	
SSUE	DATE	DESCRIPTION	CHECKED BY:	CD	

A8000 OPEN FRONT 1105 WIDE X 2180 LONG PLATFORM

A8 TD 01

DIMENSIONS IN MM

1 of 1