


DOOR POSITIONS & HANDINGS



ALTERNATIVE PLATFORM SIZES

ALTERNATIVE PLATFORM SIZES

PLATFORM SIZE	FOOTPRINT
1105 WIDE X 2180 LONG	1630 WIDE X 2380 LONG
1405 WIDE X 1980 LONG	1930 WIDE X 2180 LONG
1405 WIDE X 2480 LONG	1930 WIDE X 2680 LONG

*SIZE SHOWN ON THIS DRAWING

DOOR OPENING WIDTH
1300mm

*1200mm if fire doors installed







CIBES LIFT UK LTD
HEAD OFFICE
CHAPEL HOUSE
LEICESTER ROAD, LOUGHBOROUGH
LE11 3JF
TELEPHONE: 01509 436 022
CENTRE OF EXCELLENCE
UNITS 2 & 3 ENTERPRISE HOUSE, THOMLINSON
ROAD, HARTLEPOOL
TS25 1NS
TELEPHONE: 01429 426222

GENERAL NOTES

- 1) A 130MM DEEP PIT IS REQUIRED ON SITE FOR THE LIFT TO SIT INTO TO GIVE LEVEL ACCESS AT THE LOWER FLOOR (130MM PIT +6MM/-0MM)
- 2) IT WILL BE NECESSARY FOR THE BUILDER TO PROVIDE SUPPORT FOR THE LIFT ON SIDE D
- 3) THE SUPPORT WALL MUST BE PLUMB TO ± 5 MM. THE RELATIONSHIP BETWEEN THE LIFT BASE AND THE WALL / FIXING LOCATION IS TO BE PLUMB AND SQUARE -0/+10MM.
- 4) THE FLOOR TO CEILING HEIGHT REQUIRED IS A MINIMUM OF 2300 (WITH PIT - 2430 NO PIT). A CLEAR HEADROOM OF 2400MM WOULD BE REQUIRED ABOVE THE UPPER FLOOR LEVEL IN ORDER TO FIT A STANDARD UNIT.
- 5) THE STANDARD COLOUR OF THE PLATFORM LIFT SHAFT PANELS IS WHITE RAL 9016 FINISH. OTHER COLOURS ARE AVAILABLE ON REQUEST.
- 6) THE UNIT IS RATED AT 1000KG AS STANDARD
- 7) OTHER LIFT SIZES ARE AVAILABLE. PLEASE CONTACT THE OFFICE FOR OTHER OPTIONS.

ELECTRICS

THREE PHASE SUPPLY:
A PERMANENT 415V 3 PHASE 50HZ SUPPLY IS REQUIRED (4 WIRE - NEUTRAL & EARTH) PROTECTED BY A 20 AMP FUSED AND **LOCKABLE ISOLATOR** TO BE POSITIONED EXTERNALLY OF THE LIFT ENCLOSURE. SUPPLIED AND FITTED BY OTHERS WITHIN 500MM OF THE ELECTRICAL COMPARTMENT.



A8000

DO NOT SCALE - IF IN DOUBT ASK

NOTE: GLASS SHAFT PANELS ARE SHOWN FOR ILLUSTRATION PURPOSES ONLY.
WHITE STEEL SHAFT PANELS ARE PROVIDED AS STANDARD.
REFER TO QUOTATION FOR DETAILS

DIMENSIONS IN MM

SCALE
NTS

DRAWING TITLE: A8000 OPEN FRONT 1405 WIDE X 1980 LONG PLATFORM

DWG No. A8 TD 03 ISSUE: A PAGE: 1 of 1