


DOOR POSITIONS & HANDINGS

ALTERNATIVE PLATFORM SIZES



CIBES LIFT UK LTD
HEAD OFFICE
 CHAPEL HOUSE
 LEICESTER ROAD, LOUGHBOROUGH
 LE11 2AF
 TELEPHONE: 01509 436 022
CENTRE OF EXCELLENCE
 UNITS 2 & 3 ENTERPRISE HOUSE, THOMLINSON
 ROAD, BARTLEPOOL,
 TS25 1NS
 TELEPHONE: 01429 426222



PLATFORM SIZE	FOOTPRINT
1105 WIDE X 2180 LONG	1630 WIDE X 2380 LONG
1405 WIDE X 1980 LONG	1930 WIDE X 2180 LONG
1405 WIDE X 2480 LONG	1930 WIDE X 2680 LONG

*SIZE SHOWN ON THIS DRAWING

DOOR OPENING WIDTH
1300mm

*1200mm if fire doors installed

GENERAL NOTES

- 1) A 130MM DEEP PIT IS REQUIRED ON SITE FOR THE LIFT TO SIT INTO TO GIVE LEVEL ACCESS AT THE LOWER FLOOR (130MM PIT +6MM/-0MM)
- 2) IT WILL BE NECESSARY FOR THE BUILDER TO PROVIDE SUPPORT FOR THE LIFT ON SIDE D
- 3) THE SUPPORT WALL MUST BE PLUMB TO ± 5 MM. THE RELATIONSHIP BETWEEN THE LIFT BASE AND THE WALL / FIXING LOCATION IS TO BE PLUMB AND SQUARE -0/+10MM.
- 4) THE FLOOR TO CEILING HEIGHT REQUIRED IS A MINIMUM OF 2300 (WITH PIT - 2430 NO PIT). A CLEAR HEADROOM OF 2400MM WOULD BE REQUIRED ABOVE THE UPPER FLOOR LEVEL IN ORDER TO FIT A STANDARD UNIT.
- 5) THE STANDARD COLOUR OF THE PLATFORM LIFT SHAFT PANELS IS WHITE RAL 9016 FINISH. OTHER COLOURS ARE AVAILABLE ON REQUEST.
- 6) THE UNIT IS RATED AT 1000KG AS STANDARD
- 7) OTHER LIFT SIZES ARE AVAILABLE. PLEASE CONTACT THE OFFICE FOR OTHER OPTIONS.


ELECTRICS

THREE PHASE SUPPLY:




A PERMANENT 415V 3 PHASE 50HZ SUPPLY IS REQUIRED (4 WIRE - NEUTRAL & EARTH) PROTECTED BY A 20 AMP FUSED AND **LOCKABLE ISOLATOR**. THE ISOLATOR TO BE POSITIONED EXTERNALLY OF THE LIFT ENCLOSURE. SUPPLIED AND FITTED BY OTHERS WITHIN 500MM OF THE ELECTRICAL COMPARTMENT.

LIFTING EYE OR BEAM TO BE SUPPLIED BY OTHERS (SWL 500KG) APPROX 250MM ABOVE LIFT

E160 FIRE RATED STEEL DOOR WITH VISION PANEL. RAL 9016 FINISH



ACCESS REQUIRED FOR ELECTRICAL COMPARTMENT AND EMERGENCY BATTERY LOWERING



A8000

DO NOT SCALE - IF IN DOUBT ASK

A	24/11/2016	INITIAL DRAWING	DRAWN BY:	CT
ISSUE	DATE	DESCRIPTION	CHECKED BY:	CD

DRAWING TITLE: **A8000 OPEN FRONT 1405 WIDE X 2480 LONG PLATFORM [FIRE DOORS]**

DIMENSIONS IN MM

SCALE
NTS

DWG No. **A8 TD 06**

ISSUE: **A** PAGE: **1 of 1**